



RAPID CONTROLS PVT.LTD.

B-47, Mayapuri, Indl. Area, Phase-1, New Delhi-64 (India)

Phone - 28117185, 28113873, 28115349, 45128360

E-mail : rapidcontrols@gmail.com, rapidcontrols47@gmail.com

Website : www.rapidcontrols.co.in

TECHNICAL DATA SHEET

TEST POINT

S.No.	DESCRIPTION	DETAILS
1	BODY BODY	BRASS IS:319 GRADE DCD GEADE - /II/IS:8737
2	BUSH LOCK	NYLON MOLDED
3	SEALING BUSH	NEOPRENE RUBBER
4	TOP COVER	NYLON MOLDED
5	TOP COVER SEAT	NITRILE BUTANE RUBBER
6	WORKING TEMP	-15°C-150°C
7	WORKING PRESSURE	20 Kg/cm ²
8	TEST PRESSURE	HYDROSTATIC @ 32 Kg/cm ² (456 P.S.I.G.)
9	END CONNECTION	MALE SCREWED END ¼" BSP(M)(6MM)
10	MAKE	RC
11	MADE IN	INDIA

